

□ Routine Maintenance

- If the valve is equipped with position indicator lights, verify that all lights are functional. Next, verify the position indicated is the actual position of the valve. Consult the electric actuator manual concerning any electrical problems.

4.3 LUBRICANTS

When lubrication is called for, Hale Products, Inc. recommends using one of the following lubricants:

- **Never-Seez®**, White Food Grade with PTFE, manufactured by:
Bostik Findley, Inc.
211 Boston Street, Middleton, MA 01949-2128
web: www.bostikfindley-us.com
- **White Knight™**, Food Grade Anti-Seize Compound, manufactured by:
Jet Lube Inc.
4849 Homestead Road, Suite 500, Houston, TX 77028
Web www.jetlube.com
- **Anti-Seize™**, manufactured by:
U.S. Valve Service & Training, Inc.
11875 West Little York, Suite 502, Houston, TX 77041
Web www.usvalveservices.com/prod7.htm